



# Town of Halton Hills Green Development Standards v3



JUNE 15, 2021

# Contents

- 1. Energy & Water ..... 4
  - 1.1 Energy Use Reduction ..... 5
  - 1.2 Low Carbon Energy..... 8
  - 1.3 Water Use Reduction ..... 10
  - 1.4 Energy and Water Reporting..... 11
- 2. Ecology..... 12
  - 2.1 Minimum Soil Depth ..... 13
  - 2.2 Minimum Planter Soil Volume ..... 14
  - 2.3 Native & Drought Resistant Vegetation..... 15
- 3. Resiliency ..... 16
  - 3.1 Stormwater Quantity..... 17
  - 3.2 Stormwater Quality ..... 18
  - 3.3 Resiliency Checklist ..... 19
- 4. Transportation ..... 20
  - 4.1 Transportation Demand Management Plan ..... 21
- 5. Innovation ..... 24
  - 5.1 Innovation..... 25
- Definitions..... 26

# Introduction & Overview of Measures

The original version of the Green Development Standards (GDS) was introduced in 2010 and subsequently updated in 2014 to include industrial, commercial, institutional and multi-unit residential buildings. This most recent update to the Standards is version 3. GDS v3 will be applicable to all developments and major additions subject to an Official Plan and/or Zoning By-law Amendment, Draft Plan of Subdivision, or Site Plan Control approval as of June 15, 2021.

GDS v3 has been put in place to further elevate the sustainability performance of new developments in Halton Hills, and to ensure alignment with current best practices in sustainable building and development. The Town of Halton Hill’s Climate Change Emergency Declaration issued in May 2019, which established community-wide net-zero carbon goals, is a key priority that has shaped GDS v3. Given this, while GDS v3 builds on the successful tenets of the previous versions, it puts increased weight on measures that reduce the greenhouse gas intensity of developments. This change will ensure that new developments are aligned with the Town’s strategy for responding to climate change, which forms an integral component of the Town’s overall strategy for striving towards net-zero energy.

The measures incorporated into GDS v3 were established through: a review of relevant industry standards and guidelines; a review of other municipal green development standards across Canada; and several rounds of consultation with various private and public sector stakeholders.

GDS v3 has also been developed to work with, and build upon, existing legislation and policy (e.g. Ontario Building Code, Provincial Policy Statement, The Planning Act, A Place to Grow: The Growth Plan for the Greater Golden Horseshoe, Made-in-Ontario Environment Plan) and existing municipal and provincial goals and priorities. Nevertheless, because every development site is different and legislation is always changing, conflicts between the GDS v3 requirements and those of other authorities having jurisdiction could arise. Should this occur, the developer should point the Town and the other authority having jurisdiction to the conflict. These parties will then identify the appropriate site-specific approach in collaboration with the development team, which in most cases would see the more stringent of the requirements prevailing.

GDS v3 consists of 12 measures, that are organized into 5 categories:

- 1. Energy & Water
- 2. Ecology
- 3. Resiliency
- 4. Transportation
- 5. Innovation

Each measure has points associated with it. To be compliant with GDS v3, all new developments and major additions that submit a rezoning, subdivision, or site plan control application must demonstrate achievement of at least 20 points.

The next page includes a checklist summarizing the submission requirements, performance thresholds, and points associated with each measure. The pages that follow this checklist summary list details on the requirements, submission documentation, rationale, and resources for each measure.

# Town of Halton Hills Green Development Standards Summary Checklist

Project Address / Name: 14015 Danby Rd App. #: \_\_\_\_\_  
 Contact Name & Email: Carly Forrester  
cforrester@kindredworks.ca Date: Dec 16, 2022

	Submission Requirements	Theshold & Potential Points			Targeted Points
<b>Energy &amp; Water</b>					
<b>1.1: Energy Use Reduction</b> Demonstrate reduction in energy use over code minimum with an energy model reflecting the proposed design. Low-rise residential (i.e. OBC's Part 9) minimum is 10%. Minimum for everything else is 15%.	<input type="checkbox"/> Energy report <input type="checkbox"/> Energy model file <input type="checkbox"/> Envelope design brief <input type="checkbox"/> Mech. & elec. design brief	Part 3	Part 9	Pts	
		15%	10%	5	
		25%	20%	8	
		40%		11	
		Net-Zero		14	
<b>1.2: Low Carbon Energy</b> Utilize low emission mechanical systems, and/or install onsite renewables, to achieve an incremental percent CO2e reduction beyond the percent energy use reduction demonstrated for measure 1.1.	<input type="checkbox"/> All above items <input type="checkbox"/> Supporting CO2e calculations <input type="checkbox"/> Renewable energy calculations (if applicable)	+ 5%		1	
		+ 10%		2	
		+ 15%		3	
		+ 20%		4	
<b>1.3: Water Use Reduction</b> Specify maximum water fixture flow rates that achieve potable water consumption reductions over OBC maximum rates.	<input type="checkbox"/> Completed water reduction calculator	30%		1	
		40%		2	
<b>1.4: Energy &amp; Water Reporting</b> Report key performance characteristics for development. Declare that this data can be made publically accessible.	<input type="checkbox"/> Signed declaration letter listing all performance metrics	If provided		1	
<b>Ecology</b>					
<b>2.1: Minimum Soil Depth</b> Preserve or re-instate a minimum depth of at least 30cm of high quality topsoil across the site.	<input type="checkbox"/> Signed narrative describing strategy	30cm		1	
<b>2.2: Minimum Planter Soil Volume</b> Provide a minimum of 30m3 of soil volume per tree.	<input type="checkbox"/> Landscaping drawings noting strategy	30m3		1	

	Submission Requirements	Threshold & Potential Points		Targeted Points
<b>2.3: Native &amp; Drought Resistant Vegetation</b> Demonstrate that there is no need for site irrigation, or that at least 75% of vegetation will be native and/or drought-tolerant.	<input type="checkbox"/> Landscaping drawings noting strategy	75%	1	
<b>Resiliency</b>				
<b>3.1: Stormwater Quantity</b> Retain run-off from a minimum of 10-mm depth of rainfall from all site surfaces through infiltration, evapotranspiration, and reuse	<input type="checkbox"/> Stormwater management plan and supporting calculations	10mm	2	
		27mm	3	
<b>3.2: Stormwater Quality</b> Remove at least 85% of total suspended solids from run-off leaving the site.	<input type="checkbox"/> Stormwater management plan and supporting calculations	85%	1	
<b>3.3: Resiliency Checklist</b> Complete resiliency checklist to demonstrate awareness of site climate change risks.	<input type="checkbox"/> Completed climate change resiliency checklist	If provided	1	
<b>Transportation</b>				
<b>4.1: TDM Plan &amp; Electric Vehicles</b> Demonstrate a percent reduction in fossil fuel single occupancy vehicle trips for the site through: cycling, walking, transit, and/or electric vehicle infrastructure.	<input type="checkbox"/> Transportation demand management plan with supporting calculations	30%	4	
		50%	5	
		70%	6	
		90%	7	
<b>Innovation</b>				
<b>5.1: Innovation</b> Quantitively demonstrate that another strategy achieves environmental benefits equal or greater than other GDS measures.	<input type="checkbox"/> Narrative and calculations supporting the case	Case for number of eligible points to be made by applicant	1	
			2	
			3	
			4	
			5	

**Total Targeted Points:**  
(minimum of 20 required)

23

# 1. Energy & Water

Acting on the Climate Emergency as declared by the Town of Halton Hills in May 2019, these measures will help mitigate climate change by ensuring that new developments are designed to higher performance energy and water use thresholds, and by encouraging renewable energy generation.



## 1.1 Energy Use Reduction

<p><b>Requirements for Part 3 Buildings</b></p>	<p>Part 3 buildings (i.e. <b>all mid to high-rise residential, and all non-residential</b>) shall demonstrate a minimum energy performance level of at least the percent shown in the below table, better than that of the Ontario Building Code's 2017 Supplementary Standard SB-10 Divisions 1 and 3.</p> <table border="1" data-bbox="576 478 1344 617"> <tr> <td>Threshold:</td> <td>15%</td> <td>25%</td> <td>40%</td> <td>Net-zero Energy</td> </tr> <tr> <td>Points:</td> <td>5</td> <td>8</td> <td>11</td> <td>14</td> </tr> </table> <p>Compliance with this pathway shall be demonstrated using an energy model for the entire building project, using an approved third-party building energy simulation software. Acceptable software includes eQuest, EnergyPlus, and IES Virtual Environment. The energy model must be completed using industry best practices and in accordance with the requirements of SB-10 Division 3, except for the following exception: once the 15% minimum threshold is demonstrated, onsite renewable energy can be used to reach higher thresholds.</p>	Threshold:	15%	25%	40%	Net-zero Energy	Points:	5	8	11	14
Threshold:	15%	25%	40%	Net-zero Energy							
Points:	5	8	11	14							
<p><b>Requirements for Part 9 Buildings</b></p>	<p>Part 9 buildings (i.e. <b>low-rise residential</b>) shall be designed to meet or exceed the minimum energy performance level of at least the percent shown in the below table, better than that of the Ontario Building Code's 2017 Supplementary Standard SB-12.</p> <table border="1" data-bbox="576 1094 1344 1232"> <tr> <td>Threshold:</td> <td>10%</td> <td>20%</td> <td>40%</td> <td>Net-zero Energy</td> </tr> <tr> <td>Points:</td> <td>5</td> <td>8</td> <td>11</td> <td>14</td> </tr> </table> <p>Compliance with this pathway shall be demonstrated using the computer simulation software HOT2000 (v10.51 or later). Other software allowed under Section A-2.1.2.1 of SB-12 may be accepted at the discretion of the Town's Administration. The energy model must be completed using industry best practices and in accordance with the requirements of SB-12, except for the following exception: once the 10% minimum threshold is demonstrated, onsite renewable energy can be used to reach higher thresholds.</p>	Threshold:	10%	20%	40%	Net-zero Energy	Points:	5	8	11	14
Threshold:	10%	20%	40%	Net-zero Energy							
Points:	5	8	11	14							
<p><b>Submission Documentation</b></p>	<ol style="list-style-type: none"> <li>1. Energy performance report that includes at a minimum:             <ol style="list-style-type: none"> <li>a) Summary of key energy model inputs and building characteristics;</li> <li>b) Annual building energy usage broken down by end-uses and fuel-type; and</li> <li>c) Explanation of any externally calculated energy performance or modelling software limitations.</li> </ol> </li> <li>2. Simulation files and any external calculations.</li> <li>3. Building Envelope Design Brief on designer's letterhead.</li> <li>4. Mechanical and Electrical Design Brief(s) on designer's letterhead.</li> </ol>										

## Rationale

The Town of Halton Hills' focus on reducing greenhouse gas emissions requires the inclusion of an energy-use reduction metric for new developments. The above better than reference building approach was chosen for its flexibility and familiarity in the industry. Currently, the 15% better than SB-10 pathway follows similar municipal level green standard approaches (e.g. the Toronto Green Standard), to incrementally improve energy efficiency without significantly altering the economic feasibility of that development.

In the City of Toronto's Zero Emissions Building Framework, which forms the background of the Toronto Green Standard's energy performance requirements, the economic implications of higher performance buildings were quantified in a costing exercise. That study estimated a construction cost premium for reaching performance 15% better than SB-10 2017 requirements to be around: 0.5% for multi-unit residential building that fall under Part 3 of the OBC; 0.7% for retail buildings; and 2.3% for commercial office buildings.

Because the above-mentioned costing was for Part 3 buildings only, a costing exercise was also performed for three Part 9 building typologies: a large single family detached home; a townhouse, and a low-rise multi-unit residential. Two potential paths were costed for each typology, one that includes air tightness testing, and a second path that does not require air tightness testing. The resulting estimates are summarized below.

Description	Large Single Family Detached, 10% better than SB-12 Example		Townhouse, 10% better than SB-12 Example		Multi-unit Residential, 10% better than SB-12 Example	
	2-storey with basement, Above grade: 3,680 ft <sup>2</sup>		3-storeys, Above grade: 1,900 ft <sup>2</sup>		3-storeys, 15 units, above grade: 18,782 ft <sup>2</sup>	
Example Suite of Additional Measures Above SB-12	2.5 ACH DHW 94% TE ER29 windows R-5 exterior insulation	DHW 94% TE ER29 windows R-5 exterior insulation R-10 underslab	3.0 ACH Heating & DHW 95% TPF ER29 windows Remove R-5 ext. insul.	Heating & DHW 95% TPF ER29 windows	3.0 ACH Heating & DHW 95% TPF ER29 windows Remove R-5 ext. insul.	Heating & DHW 95% TPF ER29 windows
Annual Energy Use Savings Above Code	4,978 ekWh	5,495 ekWh	4,191 ekWh	4,512 ekWh	39,968 ekWh (for building)	37,070 ekWh (for building)
Annual CO <sub>2</sub> e Savings	984 CO <sub>2</sub> e	891 CO <sub>2</sub> e	744 CO <sub>2</sub> e	685 CO <sub>2</sub> e	7,233 CO <sub>2</sub> e (for building)	6,734 CO <sub>2</sub> e (for building)
Annual Energy Cost Savings	\$132	\$121	\$161	\$168	\$60	\$53
Estimated Capital Cost Increase	\$5,747	\$8,652	-\$288	\$2,036	\$60	\$1,001
Comments	Meets ESNH BOP requirements, includes fee/model type to verify compliance and air test	No air test, rental mech unit, added fee for modeling	Meets ESNH BOP requirements, includes fee/model type to verify compliance and air test. Removal of ci results in capital cost savings.	No air test, rental mech unit, added fee for modeling	Meets ESNH BOP requirements, includes fee/model type to verify compliance and air test. Cost is per unit within MURB	No air test, rental mech unit, added fee for modeling (typically done as entire block)



## Resources

- The City of Toronto Zero Emissions Buildings Framework <https://www.toronto.ca/wp-content/uploads/2017/11/9875-Zero-Emissions-Buildings-Framework-Report.pdf>
- ENERGY STAR for New Homes <https://www.nrcan.gc.ca/energy/efficiency/housing/new-homes/energy-starr-new-homes-standard/14286>
- Ontario Building Code Supplementary Standard SB-10 <http://www.mah.gov.on.ca/Page15255.aspx>
- Ontario Building Code Supplementary Standard SB-12 <http://www.mah.gov.on.ca/Page15256.aspx>
- National Energy Code of Canada for Buildings 2015 (NECB 2015)
- ANSI/ASHRAE/IES Standard 90.1-2013
- Industry best practices energy modelling guidelines:
  - a. Energy Efficiency Report Submission & Modelling Guidelines for the Toronto Green Standard Version 3 <https://www.toronto.ca/city-government/planning-development/official-plan-guidelines/toronto-green-standard/toronto-green-standard-version-3/energy-modelling-guidelines-version-3/>
  - b. Energy Modelling Guidelines for the BC Hydro Commercial New Construction Program <https://www.bchydro.com/content/dam/BCHydro/customer-portal/documents/power-smart/builders-developers/energy-modeling-guidelines.pdf>

## 1.2 Low Carbon Energy

<b>Requirements</b>	<p>All buildings can achieve the below points by demonstrating additional percent reductions in carbon dioxide equivalency (CO<sub>2e</sub>) emissions beyond that of the energy efficiency reduction that they have already demonstrated under <i>1.1 Energy Use Reduction</i>.</p>									
	<table border="1" data-bbox="483 411 1365 682"> <thead> <tr> <th data-bbox="483 411 740 594">Incremental Percentage Point Increase in CO<sub>2e</sub> beyond 1.1 Energy Use Reduction Percent:</th> <th data-bbox="740 411 898 594">Energy Reduction Percent, Plus 5%</th> <th data-bbox="898 411 1053 594">Energy Reduction Percent, Plus 10%</th> <th data-bbox="1053 411 1209 594">Energy Reduction Percent, Plus 15%</th> <th data-bbox="1209 411 1365 594">Energy Reduction Percent, Plus 20%</th> </tr> </thead> <tbody> <tr> <td data-bbox="483 594 740 682">Points:</td> <td data-bbox="740 594 898 682">1</td> <td data-bbox="898 594 1053 682">2</td> <td data-bbox="1053 594 1209 682">3</td> <td data-bbox="1209 594 1365 682">4</td> </tr> </tbody> </table> <p>Compliance with this measure shall be demonstrated using the same energy model and results submitted for <i>1.1 Energy Use Reduction</i>. No change to that model is needed to apply for additional points under this measure.</p> <p>All of the same modelling rules described under measure <i>1.1 Energy Use Reduction</i> apply here, except that the following alternations can be made to the already modelled reference building's results:</p> <ul style="list-style-type: none"> <li>The CO<sub>2e</sub> emission benefits associated with the proposed design's renewable energy (if applicable), can be added as a debit to the reference building's CO<sub>2e</sub> number (therefore making the reference building's CO<sub>2e</sub> higher) ; and</li> <li>Natural gas CO<sub>2e</sub> emission factors can be applied to the reference building's modelled heating and domestic hot water heating energy uses, regardless of the reference building system's fuel source.</li> </ul> <p>CO<sub>2e</sub> emissions factors from SB-10's Division 3 Table 1.1.2.2 are to be used for this measure. Different CO<sub>2e</sub> factors may be used with appropriate methodological justification, and at the discretion of the Town's Administration.</p> <p>If considering renewables, the development must also consult with Halton Hills Hydro Inc. to confirm the applicability and site-specific requirements for an on-site renewable generation system within the local infrastructural context.</p>	Incremental Percentage Point Increase in CO <sub>2e</sub> beyond 1.1 Energy Use Reduction Percent:	Energy Reduction Percent, Plus 5%	Energy Reduction Percent, Plus 10%	Energy Reduction Percent, Plus 15%	Energy Reduction Percent, Plus 20%	Points:	1	2	3
Incremental Percentage Point Increase in CO <sub>2e</sub> beyond 1.1 Energy Use Reduction Percent:	Energy Reduction Percent, Plus 5%	Energy Reduction Percent, Plus 10%	Energy Reduction Percent, Plus 15%	Energy Reduction Percent, Plus 20%						
Points:	1	2	3	4						
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>All of the same documentation submitted under 1.1 Energy Use Reduction will be required for claiming points under this measure, but with an additional CO<sub>2e</sub> calculation and supporting narrative added to the energy report.</li> <li>For development's with renewable energy, analysis and calculations should be performed using a third-party renewable energy modelling tool, such as RETScreen, or other reputable energy simulation software.</li> </ol>									

## Measure Rationale

As an example, if an applicant demonstrated a 20% energy performance improvement over the reference building for measure *1.1 Energy Use Reduction*, it would be eligible for additional points under this *1.2 Low Carbon Energy* measure if it could demonstrate that the proposed design's CO<sub>2</sub>e was 25% or better than the altered reference building results (i.e. an incremental increase of at least 5 percentage points above the 20% energy improvement originally demonstrated).

In support of the Town of Halton Hill's goal to be a Net Zero municipality by 2030, all new developments should be encouraged to explore technologies and strategies that result in lower CO<sub>2</sub>e intensity (e.g. electrification, air-source heat pumps, geo-exchange, wind, photovoltaics, solar thermal, solar ventilation preheat equipment). CO<sub>2</sub>e is being used here to encompass the climate change impacts of all relevant greenhouse gases (e.g. CO<sub>2</sub>, CH<sub>4</sub>, and N<sub>2</sub>O). By designing and constructing buildings with CO<sub>2</sub>e intensity in mind, we are also better positioning new buildings for a future that is likely to place a meaningful price on emissions.

Despite the importance of selecting strategies with lower CO<sub>2</sub>e intensity, energy modelling requirements typically require a reference building's system to take on the same fuel (and similar system type) of the proposed design. The reference building therefore also gets many of the same advantages of the proposed design, and in the case of electrification this means that reference building will also have higher efficiencies and lower CO<sub>2</sub>e intensity. This measure allows for some of those reference building advantages to be diluted without requiring an additional energy model.

This measure also further incentivizes onsite renewable energy generation since the onsite renewables can earn a development points under both *1.1 Energy Use Reduction* and *1.2 Low Carbon Energy*.

## Resources

1. Halton Hills Hydro Inc. Guidelines for Applicants Connecting Distributed Generation <https://storage.googleapis.com/website-245714.appspot.com/1/2017/12/HHHI-Guidelines-for-Applicants-Connecting-DG-Public-Document-April-2015.pdf>
2. NRCan RETScreen software <https://www.nrcan.gc.ca/maps-tools-publications/tools/data-analysis-software-modelling/retscreen/7465>
3. Economics of Solar Power in Canada <https://www.cer-rec.gc.ca/nrg/sttstc/lctrct/rprt/cnmcsfslrpwr/rslts-eng.html>
4. U.S. Solar Photovoltaic System Cost Benchmark: Q1 2017 <https://www.nrel.gov/docs/fy17osti/68925.pdf>

## 1.3 Water Use Reduction

<b>Requirements</b>	<p>Specify maximum water fixture flow rates that achieve the below reductions in potable water consumption (not including irrigation) over the maximum flow rates for water supply fittings and maximum water consumption per flush cycle for sanitary fixtures listed in the Ontario Building Code article 7.6.4. Water Efficiency.</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <td style="text-align: center;">Threshold:</td> <td style="text-align: center;">30%</td> <td style="text-align: center;">40%</td> </tr> <tr> <td style="text-align: center;">Points:</td> <td style="text-align: center;">1</td> <td style="text-align: center;">2</td> </tr> </table> <p>Refer to the Ontario Building Code O.Reg 332/12 for current baseline flush and flow rates. Compliance with this requirement is demonstrated using the Indoor Water Use Reduction Calculator (found on the Town of Halton Hills website), which follows the methodology used by LEED v4 Water Efficiency Credit Indoor Water Use Reduction.</p>	Threshold:	30%	40%	Points:	1	2
Threshold:	30%	40%					
Points:	1	2					
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>Completed Indoor Water Use Reduction Calculator to demonstrate that the design fixture flush and flow rates will meet the reduction requirement.</li> </ol>						

### Measure Rationale

This measure aims to reduce potable water use in buildings by improving water-use efficiency. Doing so also reduces the energy and infrastructure required for municipal-scale treatment and distribution of potable water, and the collection and treatment of wastewater.

The minimum reduction of 30% was selected as a threshold that has proven to be feasible across residential, commercial and industrial buildings with little to no impact on capital costs or operations. For illustrative purposes, provided below are some example fixture flow rates that have been used to put residential and commercial/industrial projects within reach of the 30% threshold.

#### Typical residential targets:

- 3.8 LPM Water Closets
- 5.7 LPM Lavatory Faucets
- 6.8 LPM Shower Head Fixtures
- 6.0 LPM Kitchen Faucets

#### Typical commercial / industrial targets:

- 3.8 LPM Water Closets
- 0.5 LPM Urinals
- 1.8 LPM Lavatory Faucets
- 6.8 LPM Shower Head Fixtures
- 6.0 LPM Kitchen Faucets

### Resources

- Indoor Water Use Reduction Calculator ([found here](#))
- LEED v4 WE credit Indoor Water Use Reduction <https://www.usgbc.org/credits/new-construction-core-and-shell-data-centers-new-construction-warehouse-and-distribution-cen?return=/credits/New%20Construction/v4/Water%20efficiency>

## 1.4 Energy and Water Reporting

<b>Requirements</b>	<p>Using the development's energy model (see <i>1.1 Energy Use Reduction</i> measure) and indoor water use reduction calculator (see <i>1.3 Water Use Reduction</i> measure), document and make public the project's modelled absolute performance.</p> <ul style="list-style-type: none"> <li>• Total Energy Use Intensity (ekWh/m<sup>2</sup>/year).</li> <li>• Greenhouse Gas Intensity (kg CO<sub>2</sub>e/m<sup>2</sup>/year).</li> <li>• Natural Gas Consumption (ekWh)</li> <li>• Electricity Consumption (kWh)</li> <li>• Other Fuel Consumption (ekWh)</li> <li>• Thermal Energy Demand Intensity (kWh/m<sup>2</sup>/year) for:             <ol style="list-style-type: none"> <li>a. Heating; and</li> <li>b. Cooling.</li> </ol> </li> <li>• Total Indoor Water Use Intensity (m<sup>3</sup>/m<sup>2</sup>/year).</li> </ul> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <td style="padding: 5px;">Threshold:</td> <td style="padding: 5px;">Provided</td> </tr> <tr> <td style="padding: 5px;">Points:</td> <td style="padding: 5px; text-align: center;">1</td> </tr> </table>	Threshold:	Provided	Points:	1
Threshold:	Provided				
Points:	1				
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>1. Signed letter listing the above metrics and declaring that the data points can be made public. A template letter can be found on the Town's website <a href="#">here</a>.</li> </ol>				

### Rationale

This measure is included to create the transparency required for future energy plans, analysis and benchmarking. As more developments (of varying types, sizes and designs) upload energy, greenhouse gas and thermal energy data, a better understanding of the energy consumption associated with the Town's built environment can be achieved. This will inform future energy reduction targets, provide helpful comparisons between different developments, help identify new emerging best-practices throughout the industry, and facilitate the tracking of energy consumption trends over time.

### Resources

- Template declaration letter for 1.4 Energy and Water Reporting ([found here](#))
- Energy Efficiency Report Submission & Modelling Guidelines for the Toronto Green Standard Version 3 <https://www.toronto.ca/city-government/planning-development/official-plan-guidelines/toronto-green-standard/toronto-green-standard-version-3/energy-modelling-guidelines-version-3/>

# 2. Ecology

To help maintain and restore the Town's natural water infiltration, watershed, and ecological environment.



## 2.1 Minimum Soil Depth

<b>Requirements</b>	<p>Preserve or re-instate a minimum topsoil depth of 30cm, or 45cm where soil has been compacted, across the site with a high-quality soil composition that is at least as good as pre-development conditions.</p> <table border="1" data-bbox="657 369 1190 516"> <tr> <td data-bbox="657 369 813 457">Threshold:</td> <td data-bbox="813 369 1190 457">30 cm (or 45cm where compacted)</td> </tr> <tr> <td data-bbox="657 457 813 516">Points:</td> <td data-bbox="813 457 1190 516">1</td> </tr> </table> <p>High quality soil is well drained, un-compacted soil that is comprised of 5 to 15 % organic material with a pH level of 6.0 to 8.0. If native soil does not meet these criteria, consultation with Town staff would be necessary to establish an alternative approach to compliance.</p>	Threshold:	30 cm (or 45cm where compacted)	Points:	1
Threshold:	30 cm (or 45cm where compacted)				
Points:	1				
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>1. Narrative describing the strategy for achieving minimum soil depth coverage and indicating both the existing and targeted post-development soil composition and percolation rates.</li> </ol>				

### Rationale

To promote natural infiltration, provide a nutrient rich seedbed for the germination and rooting of local plant species, and nurture a community of beneficial micro-organisms that play a vital role in decomposition and the recycling of nutrients.

The 30cm depth was established from the Sustainable Technologies Evaluation Program, outlined in their analysis *Preserving and Restoring Healthy Soil: Best Practices for Urban Construction*. This depth of topsoil re-instatement ensures proper site drainage and ecological balance.

### Resources

1. TRCA Preserving and Restoring Healthy Soil: Best Practices for Urban Construction
2. Credit Valley Conservation Authority Case Study: Schoolyard Transformation in Progress

## 2.2 Minimum Planter Soil Volume

<b>Requirements</b>	<p>Provide a minimum of 30 m<sup>3</sup> of soil volume per individual tree on-site, and 20 m<sup>3</sup> per tree for grouped plantings (e.g. 80 m<sup>3</sup> for four trees).</p> <table border="1" data-bbox="753 348 1092 464"> <tr> <td>Threshold:</td> <td>30m<sup>3</sup></td> </tr> <tr> <td>Points:</td> <td>1</td> </tr> </table>	Threshold:	30m <sup>3</sup>	Points:	1
Threshold:	30m <sup>3</sup>				
Points:	1				
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>1. Landscape drawing(s) indicating:             <ol style="list-style-type: none"> <li>a) Tree locations</li> <li>b) Planter type(s)</li> <li>c) Soil quality per installation</li> </ol> </li> </ol>				

### Rationale

Providing trees throughout the site with enough soil area to grow to maturity will improve local ecology, soil stability, and reduce the heat island effect.

The 30m<sup>3</sup> threshold is established from previous precedents set in municipalities such as York Region, Toronto, Markham, and Oakville. Successful implementation of planter soil minimums has resulted in more robust tree vegetation and other ecological benefits (e.g. increased local flora and fauna).

### Resources

1. "Ontario Sets Standard for the Urban Forest", 2015, Michael James
2. City of Markham, Streetscape Manual, 2009
3. Soil Volume Minimum for Street Trees Established in Oakville, ON, 2012

## 2.3 Native & Drought Resistant Vegetation

<b>Requirements</b>	<p>Demonstrate that no potable water will be needed for irrigation, or ensure that at least 75% of specified vegetation shall be native and/or drought-tolerant species.</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <td style="padding: 5px;">Threshold:</td> <td style="padding: 5px; text-align: center;">75%</td> </tr> <tr> <td style="padding: 5px;">Points:</td> <td style="padding: 5px; text-align: center;">1</td> </tr> </table> <p>For sites within Conservation Halton Regulated Areas and/or Natural Heritage System Areas, 100% of plantings must be native. Note that in these instances, the site would also be subject to Conservation Authority regulations.</p>	Threshold:	75%	Points:	1
Threshold:	75%				
Points:	1				
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>1. Landscape drawing(s) indicating:             <ol style="list-style-type: none"> <li>a) List of all species being proposed for the site with their native / drought tolerant classification</li> <li>b) Proposed location and area of coverage of each species</li> </ol> </li> </ol>				

### Rationale

The inclusion of native species will aid in maintaining similar stormwater management to previous conditions, as well as help protect existing habitats. The inclusion of the drought-resistant vegetation will also improve site resiliency to future climate trends, which are anticipated to bring increases in the severity of storms and drought.

### Resources

1. Conservation Halton Landscaping and Tree Preservation Guide Appendix 1 (<https://conservationhalton.ca/policies-and-guidelines>)
2. The Credit Valley Conservation Plant Selection Guideline Document [www.creditvalleyca.ca/wp-content/uploads/2013/04/Credit-Valley-Conservation-Plant-Selection-Guideline-FINAL-March-2013-2.pdf](http://www.creditvalleyca.ca/wp-content/uploads/2013/04/Credit-Valley-Conservation-Plant-Selection-Guideline-FINAL-March-2013-2.pdf)
3. Fusion Landscaping: Environmental Benefits for Residential Properties, 2017, Peel Region
4. What is Fusion Landscaping? <https://www.fusionlandscapeprofessional.ca/what-is-fusion/>
5. Native and Drought Resistant Plants of Halton Region, <https://www.halton.ca/Repository/Native-Drought-Tolerant-Plant-Selections>

# 3. Resiliency

To adequately prepare infrastructure for changing climate conditions. This will take the form of stormwater management, preparedness planning and other design considerations.

### 3.1 Stormwater Quantity

<b>Requirements</b>	<p>Develop a stormwater quantity strategy to retain run-off generated from a minimum of 10-mm depth of rainfall – or as otherwise determined through consultation with Conservation Halton and the Credit Valley Conservation Authority - from all site surfaces through infiltration, evapotranspiration, and water harvesting/reuse.</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <td style="text-align: right;">Threshold:</td> <td style="text-align: center;">10mm</td> <td style="text-align: center;">27mm</td> </tr> <tr> <td style="text-align: right;">Points:</td> <td style="text-align: center;">2</td> <td style="text-align: center;">3</td> </tr> </table> <p>As the site allows, detail the quantity of water each method will yield (retention, evapotranspiration, stormwater management, etc).</p>	Threshold:	10mm	27mm	Points:	2	3
Threshold:	10mm	27mm					
Points:	2	3					
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>1. Stormwater Management Plan including:             <ol style="list-style-type: none"> <li>a) Preliminary location for designated systems on a site plan.</li> <li>b) Details on the stormwater retention measures used to retain runoff and their capacities.</li> <li>c) Calculations to verify a retention of 10mm of rainfall compared to pre-development conditions.</li> </ol> </li> </ol>						

#### Rationale

Incorporating these stormwater management measures help to improve the natural ability of water to infiltrate into the soil, but also reduce potable water consumption through greywater use. Employing a variety of strategies to retain the 10-mm depth of rainfall increases the flexibility of the measure.

The 10mm threshold aligns with best practices outlined by the similar municipal standards as of the date of GDS v3's publication. However, this 10-mm depth of rainfall is anticipated to eventually increase to the 90<sup>th</sup> percentile of harvest, which corresponds to approximately 27mm within the Region of Halton. The stormwater management standards implemented by the Ministry of Environment and Climate Change will soon require this 90<sup>th</sup> percentile of retention on-site through re-use, infiltration, evapotranspiration and other LID measures across the province.

Future CVC thresholds will seek to meet this updated provincial standard for stormwater retention.

#### Resources

1. Refer to the STEP LID Planning and Design Wiki Guide for guidance on how to design LID features to meet the design criteria ([https://wiki.sustainabletechnologies.ca/wiki/Main\\_Page](https://wiki.sustainabletechnologies.ca/wiki/Main_Page))
2. Planning & Permits — Conservation Halton (<https://conservationhalton.ca/planning-permits>)
3. Refer to STEP website (<https://sustainabletechnologies.ca/>) for costing tools, planning tools.
4. MECP's 90<sup>th</sup> percentile – 27 mm  
[http://www.downloads.ene.gov.on.ca/envision/env\\_reg/er/documents/2017/012-9080\\_Runoff.pdf](http://www.downloads.ene.gov.on.ca/envision/env_reg/er/documents/2017/012-9080_Runoff.pdf)

## 3.2 Stormwater Quality

<b>Requirements</b>	<p>Remove 85% of Total Suspended Solids (TSS) on an annual loading basis from run-off leaving the site.</p> <table border="1" data-bbox="756 312 1127 430"> <tr> <td>Threshold:</td> <td>85%</td> </tr> <tr> <td>Points:</td> <td>1</td> </tr> </table>	Threshold:	85%	Points:	1
Threshold:	85%				
Points:	1				
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>1. Stormwater Management Plan including:             <ol style="list-style-type: none"> <li>a) List of filtration measures proposed to suite the existing site conditions.</li> <li>b) Calculation demonstrating percent TSS removed from 25mm rainfall event based on pre-existing condition</li> <li>c) Proposed location for these measures</li> </ol> </li> </ol>				

### Rationale

Removing total suspended solids (TSS) from water systems will reduce loading to municipal wastewater treatment facilities, improve aquatic ecosystems, and nurture plant life. Example strategies for achieving this removal rate are provided in the Credit Valley Conservation Authority's Low Impact Development Stormwater Management Planning and Design Guide. Some components that help remove TSS from effluent water include: bioswales; retention ponds; filters; and oil-grit separators.

The individual TSS removal rate is dependent on the specific parameters of the system, necessitating site-specific design. The applicable strategy will require the relevant calculations from the Credit Valley Conservation Authority: Low Impact Development Stormwater Management Planning and Design Guide.

For example, green roofs were noted to reduce TSS in effluent waters by 89% compared to conventional roofing systems (Van Seters et al, 2009). Similarly, infiltration trenches may reduce 70%-90% of effluent TSS depending on the design of the system. Vegetation strips were shown to demonstrate a larger variance in TSS removal (20%-80%).

### Resources

1. MOE SWM Planning & Design Manual (March 2003)
2. Wet Weather Flow Guidelines, Toronto, 2006
3. Credit Valley Conservation Authority: Low Impact Development Stormwater Management Planning and Design Guide
4. Toronto Green Standards Tier II



### 3.3 Resiliency Checklist

<b>Requirements</b>	<p>Complete the Resiliency Checklist in collaboration with the design and consulting team. This checklist is primarily an awareness exercise that requires design teams to define the key criteria to which they are designing to, and to identify the strategies they have taken to improve the resiliency of the development.</p> <table border="1" data-bbox="721 411 1162 527"> <tr> <td>Threshold:</td> <td>Checklist Provided</td> </tr> <tr> <td>Points:</td> <td>1</td> </tr> </table>	Threshold:	Checklist Provided	Points:	1
Threshold:	Checklist Provided				
Points:	1				
<b>Submission Documentation</b>	<p>Submit a completed Climate Change Resiliency Checklist. The checklist can be found on the Town of Halton Hill’s website, and contains the following sections:</p> <ul style="list-style-type: none"> <li>• <b>Focused discussion:</b> Identifying whether a designated meeting has been held to discuss climate change resiliency strategies for the development.</li> <li>• <b>Extreme temperatures:</b> Confirming design temperatures, and identifying measures that have been taken to reduce the impacts of extreme temperatures on the development.</li> <li>• <b>Flood mitigation:</b> Confirming the vulnerability of the site to flooding, the rainfall events that have been accommodated in the design, and listing the applicable measures taken to reduce the site’s vulnerability to flooding.</li> <li>• <b>Backup Power:</b> Identifying any on-site systems planned to reduce the development’s reliance on the grid, identifying any backup power systems, and if backup power is provided - the systems that the backup power will serve.</li> <li>• <b>Summary:</b> Summarize the development’s approach to resiliency.</li> </ul> <p>All parties that have contributed to the completed checklist are then expected to sign.</p>				

#### Rationale

While mitigation efforts against climate change are fundamentally important, developments must also consider adaptation strategies to improve resilience to the more extreme weather events that are becoming more frequent. The intent is to make teams more aware and mindful of how the design will accommodate future changes in climatic conditions.

#### Resources

1. Town of Halton Hills Resiliency Checklist ([found here](#))
2. Toronto’s Future Weather and Climate Drive Study: Outcomes Report, <https://www.toronto.ca/wp-content/uploads/2018/04/982c-Torontos-Future-Weather-and-Climate-Drivers-Study-2012.pdf>
3. Climate Atlas, [www.climateatlas.ca](http://www.climateatlas.ca)

# 4. Transportation

The transportation demand management (TDM) plan is used to establish estimated baseline trip generation statistics and then demonstrate a reduction in single occupancy vehicle (SOV) trips using various TDM measures. Reducing SOVs and the associated greenhouse gas (GHG) emissions is essential for the ultimate goal of reducing overall Town GHGs towards net-zero. The reduction and document submission requirements reduction percentage and submission documents must follow the requirements set out in the Town of Halton Hills Green Development Standards (GDS).

# 4.1 Transportation Demand Management Plan

<b>Requirements</b>	<p>A TDM plan must be submitted that consist of at least the below components, and collectively demonstrate the below percent reduction in fossil fuel single occupancy vehicle (SOV) trips:</p>				
	Threshold:	30%	50%	70%	90%
	Points:	4	5	6	7

- Trip Generation Statistics: Outline the base trip generation statistics and quantify the reduction in fossil fuel SOV trips due to the various TDM measures planned for implementation.
- Cycling:
  - Identify connections with existing cycling routes and destinations.
  - Describe the quantity, location, and features of both short- and long-term bicycle parking stations.
  - Describe amenity spaces for riders ending their trip at the development. This can include showers, lockers, changing rooms, etc.
- Walking:
  - Describe the walking/pedestrian networks on the development site and their connection to pedestrian routes beyond the site boundaries.
  - Describe the pedestrian amenities implemented to support active transportation, variable mobility, and safety.
- Transit:
  - Describe development’s connection with existing transit routes and stops.
  - Describe any transit service or fare incentive programs.
  - Describe any alternative commute services (e.g. dedicated shuttle buses, bike share).
- Parking and Electric Vehicle Charging:
  - List the quantity, type, and location of parking spots equipped with dedicated electric vehicle charging stations.
  - Outline the parking provisions: quantity of spaces, quantity of those reserved for tenants/employees, quantity of carpool spaces, etc.
- Wayfinding and Travel Planning:
  - Describe wayfinding and signage that will make traveling within and beyond the site easier.

Describe available resources, such as active transportation maps, customized trip planning, and community resources to assist travel decisions.

Note that this section presents minimum requirements for completion of the TDM plan and is not exhaustive. The applicant is encouraged to discuss the required contents with Town of Halton Hills staff prior to initiating the strategy.

## Submission Documentation

Provide a TDM demonstrating a strategy to reduce single-occupancy vehicle use of fossil fuel vehicles. The structure of the TDM plan will vary based on development type and location, but may employ the following strategies:

### 1. Cycling

- Information on cycling routes/destination
- Ensure there is connection to existing bicycle network
- Secure, indoor bicycle storage spaces
- Providing end-of-trip amenities for tenants/employees

### 2. Walking

- Safe and attractive walkways
- Ensure there is connection to existing sidewalk network
- Enhanced pedestrian amenities on-site

### 3. Transit

- Transit information
- Transit fare incentives
- Private transit service

### 4. Parking

- Implementation of paid parking for tenants/employees
- Cash-in-lieu of parking to fund public parking or sustainable transportation
- Provide dedicated electrical parking charging station

### 5. Alternative Commute Services

- Provide dedicated publicly available parking spaces for car share vehicles
- Provide on-site bike-share facility
- Provide improved and/or additional short-term pick-up/drop-off passenger spaces
- Provide free local shuttle bus services to between the development site and regional transit hubs, commercial centres, and residential areas for customer, employees and visitors.

### 6. Way Finding and Travel Planning

- Provide travel planning resources such as active transportation maps, community resources, etc.
- Wayfinding signage
- Personalized trip planning

### 7. Education, Promotion and Incentives

- Contribute to building a strong TDM brand
- Provide discounted transit passes, care-share memberships and/or bikeshare memberships for tenants/employees.

## Rationale

The intent is to create a plan through which fossil fuel single-occupant vehicle trips can be reduced, therefore lowering the community's associated greenhouse gas emissions.

A sample TDM calculation is provided below for illustrative purposes:

- Occupants of a multi-unit residential building: 140
- Expected visitors:  $140 \times 2\% = 7$
- Total trips:  $147 \times 2 \text{ trips per day} \times 60\% \text{ estimated working adults} = 176$  single occupancy vehicle trips
- Targeted reduction of 40%:  $176 \times 40\% = 70$

Potential path towards reducing 70 fossil fuel single-occupancy vehicle trips:

1. Install ten dedicated electric car charging stations =  $10 \times 2 \text{ trips per day} = 20$
2. Ride sharing program for commuters =  $6 \text{ Vehicles} \times 2 \text{ trips per day} = 12$
3. Locating development next to bus line =  $10 \text{ Riders} \times 2 \text{ trips per day} = 20$
4. Locating development next to bicycle network, or installing connection from development to closest access point =  $9 \text{ Riders} \times 2 \text{ trips per day} = 18$

These changes result in a decrease of  $20 + 12 + 20 + 18 = 70$  fossil fuel SOV trips.

## Resources

1. Town of Halton Hills Cycling Master Plan - <https://www.haltonhills.ca/en/residents/cycling-master-plan.aspx>
2. Town of Halton Hills Active Transportation Management Plan - <https://www.haltonhills.ca/en/residents/active-transportation-master-plan.aspx>
3. LEED v4 and October 2017 Technical Bulletin "Tips and Tricks – Transportation Demand Management (TDM) Plans" <https://www.cagbc.org/CAGBC/LEED/Technicalbulletins/CAGBC/Programs/LEED/CommercialInstitutional/FAQs.aspx?hkey=b8969ea0-ea23-4816-b7b7-0f04f5107527>
4. City of Vancouver – <https://vancouver.ca/files/cov/transportation-demand-management-for-developments-in-vancouver.pdf>
5. City of Hamilton – <https://www.hamilton.ca/develop-property/policies-guidelines/transportation-demand-management-land-development-guidelines>
6. Region of Peel – <http://walkandrollpeel.ca/projects/sts/pdf/peel-TDM-plan.pdf>
7. City of Ottawa – [https://documents.ottawa.ca/sites/documents/files/tdm\\_measures\\_checklist\\_en.pdf](https://documents.ottawa.ca/sites/documents/files/tdm_measures_checklist_en.pdf)

# 5. Innovation

Recognizing that development opportunities are constantly evolving, this category offers some additional flexibility for accommodating new and emerging ideas and technology that may not have been contemplated for GDS v3.



## 5.1 Innovation

<b>Requirements</b>	<p>Demonstrate to the satisfaction of the Town's Administration the value of an innovative green development strategy or technology being integrated into the design. Up to 5 points are available in this category. Acceptance of point threshold or a given strategy will be determined in collaboration with the Town's Planner, and based predominantly on the applicant's ability to quantitatively demonstrate that the strategy achieves environmental benefits that are the equivalent to, or greater than, other measures within GDS v3 that have a similar point threshold being claimed here.</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <td style="background-color: #e0e0e0;">Threshold:</td> <td colspan="5" style="text-align: center;">To be determined</td> </tr> <tr> <td style="background-color: #e0e0e0;">Points:</td> <td style="text-align: center;">1</td> <td style="text-align: center;">2</td> <td style="text-align: center;">3</td> <td style="text-align: center;">4</td> <td style="text-align: center;">5</td> </tr> </table>	Threshold:	To be determined					Points:	1	2	3	4	5
Threshold:	To be determined												
Points:	1	2	3	4	5								
<b>Submission Documentation</b>	<ol style="list-style-type: none"> <li>Narrative making the case for the innovative green development strategy or technology, including calculations supporting that the initiative has a quantifiable environmental impact equivalent or greater to another measure within GDS v3.</li> </ol>												

### Rationale

This measure has been included to reflect the fact that green development opportunities are constantly evolving, and to offer additional flexibility to the development team to ensure that innovation is not stifled. The hope is that this category can accommodate new and emerging ideas and technology that fall outside of those contemplated for GDS v3.

### Resources

- LEED Innovation in Design Credit Library  
<https://www.usgbc.org/innovationcatalog?Version=%22v4%22&Rating+System=%22New+Construction%22>

# Definitions

# Definitions

Building Envelope Design Brief	Description of the primary intended envelope components for the building, inclusive of minimum clearfield effective thermal performance values for opaque wall, roof, floor, and glazing systems; as well as a description of how thermal bridging will be reduced at key interfaces (e.g. wall to roof transitions, window to wall transitions, structural components, floor junctions, balconies). To be placed on architectural / envelope designer's letterhead.
Drought-resistance	Vegetation that is uniquely adept at enduring drought-conditions. These are specific to each region; <i>Native and Drought Resistant Plants of Halton Region</i> provides those specific to Halton Region.
EV Charging	Designated parking spot with EV charging capability, that has a minimum Level 2 charging capacity (208 – 240 volts, with a minimum circuit rating of 32Amps).
Greenhouse Gas Intensity (GHGI)	The annual greenhouse gas emissions resulting directly from fuel consumed on site (e.g. natural gas) or indirectly from purchased energy (e.g. electricity), per unit of modelled floor area. Measured in kg CO <sub>2</sub> e/m <sup>2</sup> /year. Greenhouse gas emission factors shall be per the Ontario Building Code 2012 Supplementary Standard SB-10 2017 Division 3, Chapter 1, Table 1.1.2.2. "CO <sub>2</sub> e Emission Factors."
Mechanical and Electrical Design Brief	Description of the key intended mechanical and electrical design attributes. It is to include a list of specific minimum energy performance metrics for space heating, space cooling, and ventilation. The brief shall also describe hot water heating strategy, and list maximum water fixture flow rates for all potable water consuming fixtures. On the electrical side, a description of the lighting strategy (fixture type, controls), and a description of renewable energy systems (if applicable). To be placed on mechanical and electrical designer's letterhead.
Modelled floor area	The total enclosed floor area of the building, as reported by the energy simulation software, excluding exterior areas and indoor parking areas. All other spaces, including partially-conditioned and unconditioned spaces are included in the modelled floor area. Measured in m <sup>2</sup> .
Part 3 Buildings	Buildings that are subject to Part 3 of Division B of the Ontario Building Code, per Article 1.1.2 O.Reg. 332/12: Building Code. This includes buildings exceeding 600 m <sup>2</sup> in building area or exceeding three storeys in height.
Part 9 Buildings	Buildings that are subject to Part 9 of Division B of the Ontario Building Code, per Article 1.1.2 O.Reg. 332/12: Building Code. This includes buildings of three or fewer storeys in height or with a building area not exceeding 600 m <sup>2</sup> .

Process energy	Energy consumed in support of a manufacturing, industrial, or commercial process other than conditioning spaces and maintaining comfort and amenities for the occupants of a building.
Renewable Energy	Renewable energy is derived from natural processes that are replenished at a rate that is equal or faster than the rate at which they are consumed. For the purposes of the GDS, eligible renewable energy systems include: photovoltaics; solar thermal; wind; and low-impact hydroelectricity. Only energy that can be consumed (or stored and then consumed) on the site shall be counted.
Single-Occupancy Vehicle (SOV)	A vehicle whose operator is the sole passenger
Thermal Energy Demand Intensity (TEDI) – Cooling	The annual heat rejection required to offset heat gain from a building's envelope and ventilation, after accounting for all passive heat gains and losses, per unit of modelled floor area. Measured in kWh/m <sup>2</sup> /year.
Thermal Energy Demand Intensity (TEDI) – Heating	The annual heat input required to offset heat loss from a building's envelope and ventilation, after accounting for all passive heat gains and losses, per unit of modelled floor area. Measured in kWh/m <sup>2</sup> /year.
Total Energy Use Intensity (TEUI)	The sum of all energy consumed on site annually (e.g. electricity, natural gas, district heat), including all process energy, per unit of modelled floor area. Measured in ekWh/m <sup>2</sup> /year.